

Efectis Nederland BV P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

CLASSIFICATION

CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2018

Classification no.	2021-Efectis-R001584
Sponsor	Wentex International BV Italiëlaan 4b 2391 PT HAZERSWOUDE-DORP THE NETHERLANDS
Product name	Medium Gloss Satin Black and white colour
Prepared by	Efectis Nederland BV
Notified body no.	1234
Author(s)	B.R. Knottnerus B.Sc. A.J. Lock
Project number	ENL-21-001068
Date of issue	December 2021
Number of pages	5





In case this report was drafted on instructions, the rights and obligations of contracting parties are subject to either the Standard Conditions of Efectis Nederland BV or the relevant agreement concluded between the contracting parties.



Efectis Nederland BV 2021-Efectis-R001584 December 2021 Wentex International BV



1. INTRODUCTION

This classification report defines the classification assigned to **Medium Gloss Satin** in accordance with the procedures given in EN 13501-1:2018.

2. DETAILS OF CLASSIFIED PRODUCT

2.1 GENERAL

The product, Medium Gloss Satin, is defined as a fabric (for application e.g. curtains for theatres, fairs and events).

2.2 IMPORTER

Wentex International BV Italiëlaan 4b 2391 PT HAZERSWOUDE-DORP THE NETHERLANDS

2.3 PRODUCT DESCRIPTION

Product description:

100% Polyester (PES) fibres woven into a fabric. The product is symmetrical. The PES fibres are manufactured in Taiwan and the fabric is woven in China.

The product has a total thickness of <1 mm and a mass per unit area of approx. 175 g/m². The product is available in the colours black and white

3. STANDARDS, REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

3.1 APPLICABLE (PRODUCT) STANDARDS

EN ISO 11925-2:2020	Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test
EN 13823:2020	Reaction to fire tests for building products - Building products, excluding floorings exposed to the thermal attack by a single burning item
EN 13238:2010	Reaction to fire tests for building products - Conditioning procedures and general rules for selection of substrates
EN 13501-1:2018	Fire classification of construction products and building elements Part 1: Classification using data from reaction to fire tests



3.2 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV	Wentex International BV	2021-Efectis-R001581	EN ISO 11925-2:2020
THE NETHERLANDS	THE NETHERLANDS	2021-Efectis-R001582	EN 13823:2020

3.3 TEST RESULTS

			Results	
Test method and test number	Parameter	No. tests	Continuous parameter – maximum	Compliance with parameters
EN ISO 11925-2				
Surface flame	Fs ≤150 mm		70	-
Impingement Black Colour	Ignition of filter paper	6	-	Compliant
Edge flame Impingement Black Colour	Fs ≤150 mm	_	70	-
	Ignition of filter paper	6	-	Compliant
Surface flame Fs ≤150 mm			35	-
Impingement White colour	Ignition of filter paper	2	-	Compliant
Edge flame Impingement Black Colour	Fs ≤150 mm		30	-
	Ignition of filter paper	2	-	Compliant

			Results		
Test method and test number	Parameter		No. tests	Continuous parameter – mean (m)	Compliance with parameters
EN 13823					
Black	FIGRA _{0.2MJ}	[W/s]		0	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s}	[MJ]		0.2	-
	LFS < edge			-	Compliant
	SMOGRA	[m²/s²]	3	0.0	-
	TSP _{600s}	[m ²]		16	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant



Efectis Nederland BV 2021-Efectis-R001584 December 2021 Wentex International BV

EN 13823					
White	FIGRA _{0.2MJ}	[W/s]		0	-
	FIGRA _{0.4MJ}	[W/s]		0	-
	THR _{600s} [MJ]			0.0	-
	LFS < edge			-	Compliant
	SMOGRA	[m²/s²]	1	0.0	-
	TSP _{600s} [m ²]			18	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant

3.4 CLASSIFICATION CRITERIA

		ion products and buildir ar pipe thermal insulation p		
Classification crit	eria			
Class Test method(s)	В	С	D	
EN ISO 11925-2 Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.			
EN 13823	$ \begin{array}{ c c c c c } FIGRA_{0.2 \text{ MJ}} \leq 120 \text{ W/s} & FIGRA_{0.4 \text{ MJ}} \leq 250 \text{ W/s} \\ LFS < edge of specimen \\ THR_{600s} \leq 7.5 \text{ MJ} & THR_{600s} \leq 15 \text{ MJ} \end{array} \end{array} FIGRA_{0.4 \text{ MJ}} \leq 7 \\ \end{array} $		FIGRA _{0.4 MJ} ≤ 750 W/s	
Additional classif	ication			
$\begin{array}{llllllllllllllllllllllllllllllllllll$				
Flaming Droplets/particles				

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2018.

4.2 CLASSIFICATION

The product, Medium Gloss Satin, in relation to its reaction to fire behaviour is classified:

в

The additional classification in relation to smoke production is:





The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0

4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness	<1 mm
Surface density	175 g/m²
Other properties	Composed of 100% Polyester (PES) fibres. Available in the colours black and white

This classification is valid for the following end use applications:

Substrate	Not applicable
Application	Free hanging
Air gap	Not applicable
Methods and means of fixing	Mechanically fixed
Joints	Yes Stiched seams
Other aspects of end use conditions	Closed surface, no openings or gaps between components

4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

Consult classification standard and national laws and regulations for limitations on the period of validity of the classification.

5. LIMITATIONS

This classification document does not represent type approval or certification of the product.

B.R. Knottnerus B.Sc. Project leader Reaction to Fire

flock

A.J. Lock Manager Testing Reaction to Fire